

Exhibit 1



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

MAR 27 2020

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

The Honorable Chokwe A. Lumumba
Mayor of City of Jackson
219 South President Street
Jackson, Mississippi 39205

Re: Emergency Administrative Order under SDWA Section 1431, 42 U.S.C. § 300i
Public Water System: City of Jackson Public Water System
PWS ID Number: MS0250008
Docket No.: SDWA-SDWA-04-2020-2300

Dear Mayor Lumumba:

Enclosed is an Emergency Administrative Order (Order) issued by the U.S. Environmental Protection Agency to the City of Jackson, Mississippi (Respondent), as the owner/operator of the City of Jackson Public Water System (System), pursuant to section 1431 of the Safe Drinking Water Act (SDWA), 42 U.S.C. § 300i.

Based on observations made by the EPA during its inspection conducted the week of February 3, 2020, and review of the documents provided by Respondent in response to the EPA's request for information issued pursuant to its authority under section 1445 of the SDWA, 42 U.S.C. § 300j-4, the EPA has determined that conditions exist at the System that present an imminent and substantial endangerment to the persons served by the System. Based on evidence of turbidity exceedances, disinfection treatment concerns, and/or the condition of the distribution system, the System has the potential to have the presence of *E. Coli*, *Cryptosporidium*, or *Giardia* in the drinking water being served to its customers. Therefore, pursuant to section 1431 of the SDWA, 42 U.S.C. § 300i, the EPA is authorized to take actions necessary to protect human health. The Order and its requirements are necessary to ensure adequate protection of public health.

The enclosed Order sets forth the actions that must be taken to ensure that the people served by the System are provided with safe drinking water. The Order requires the System to, among other things: (1) develop and implement a plan to address all monitoring equipment and appurtenant treatment equipment repairs and/or replacements; (2) address dosing processes for disinfection and pH control; (3) develop and implement a plan to provide alternative drinking water when specific triggers are met; and (4) take additional total coliform bacteria samples under prescribed conditions.

The Order constitutes a final agency action and under Section 1448(a) of the SDWA, 42 U.S.C. § 300j-7(a) you may seek federal judicial review. If you have any questions or wish to discuss this Order, please contact Amanda Driskell at (404) 562-9735 or Driskell.Amanda@epa.gov. For legal inquiries,

please have your attorneys contact Suzanne Armor, Associate Regional Counsel, at (404) 562-9701 or Armor.Suzanne@epa.gov. Thank you for your attention to this matter.

Sincerely,



Carol L. Kemker

Director

Enforcement and Compliance Assurance Division

Enclosure

cc: Robert K Miller, Director, City of Jackson Department of Public Works
Lester Herrington, Director of Office of Environmental Health,
Mississippi State Department of Health